



COMPONENT LIST			
L" DIM.	ITEM	MAKE FROM	DESCRIPTION
		P/N FT XX 12X48	CO WIRE .196 DIA
2"		2X24X24	
4"		4X24X24	
6"		6X24X24	

GENERAL NOTES:

- A) MATERIAL TO BE HOT DIPPED, PRE-GALVANIZED STEEL, ASTM A641, TO AVOID THE FORMATION OF ZINC WHISKERS.
- B) FINISH (CARBON STEEL WIRE ONLY).
 - 1) ELECTRODEPOSITED ZINC, TYPE III FINISH SERVICE CONDITION (ONE) PER ASTM B63
 - 2) POLYESTER POWDER COATING 1.2 - 3.0 MIL THICK.
- C) DIMENSIONAL TOLERANCES
 - 1) GENERAL DIMENSIONS +/- 1/8" U.N.D.
 - 2) LENGTH +/- 1/4"
 - 3) WIDTH +/- 1/8"
 - 4) DEPTH +/- 1/8"
 - 5) ANGULAR FORMATION +/- 3 DEG.
 - 6) CAMBER SHALL NOT EXCEED 1/2" ON STANDARD 10' LENGTH.
 - 7) TWIST SHALL NOT EXCEED 1/2" ON STANDARD 10' LENGTH
- D) RIB VICE DIAMETER
 - 1) .197 (5MM) DIAMETER.
- E) LONGITUDINAL WIRE DIAMETER.
 - 1) .197 (5MM) DIAMETER
- F) CROSS SECTION AREA
 AREA = (20 WIRES X .0438 IN²) = .876 IN²
 UL MARKING = .8 IN²

UNLESS OTHERWISE SPECIFIED:
DIMENSIONS ARE IN INCHES.

REVISION	NAME	CHANGE	DATE			
A	AF		3-7-10			

DEBUR AND BREAK SHARP EDGES



TITLE: FLOORFLEX-TRAY

DWG NO. FT XX 12 X 48

SHEET 1 OF 1